



West Visayas State University

(Formerly Iloilo Normal School)

Bids and Awards Committee Secretariat Office/ Procurement Section

Luna St., La Paz, Iloilo City 5000

Iloilo, Philippines

* Trunkline: (063) (033) 320-0870 loc1103/1104 * Telefax No.: (033) 320-0879

* Website: www.wvsu.edu.ph * Email Address: bac@wvsu.edu.ph



SCP000194Q

SUPPLEMENTAL/BID BULLETIN

<i>Project Reference No.</i>	IB No. 21-11-39
<i>Name of the Project</i>	Procurement of Various Air Conditioning Units
<i>Location of the Project</i>	WVSU - Main Campus

ADDENDUM NO. 2021- 32

November 15, 2021

This **Addendum No. 2021-32** is issued to modify the **Section VII. Technical Specifications and Section VIII. Checklist of Technical and Financial Documents.** These shall form an integral part of the Bidding Documents.

I. Section VII. Technical Specifications:

Item No.	Description	Corrections/ Amendments/ Instructions		
1.	AIR CONDITIONING UNIT, FLOOR MOUNTED, 3.0 TONNER, NON-INVERTER with INSTALLATION COST - CON and COM	AIR CONDITIONING UNIT, FLOOR MOUNTED, 3.0 TONNER, NON-INVERTER with INSTALLATION COST - CON and COM		
	<i>Qty/ Unit: 2 units</i>	<i>Qty/ Unit: 2 units</i>		
	<i>Brand: (pls. indicate brand)</i>	<i>Brand: (pls. indicate brand)</i>		
	<i>Model: (pls. specify model)</i>	<i>Model: (pls. specify model)</i>		
	<i>Capacity (Tonner)</i>	3.0	<i>Capacity (Tonner)</i>	3.0
	<i>Power Input (W)</i>	3,100 or lower	<i>Power Input (W)</i>	3,100 or higher
	<i>Rated Current (A)</i>	16.7 or lower	<i>Rated Current (A)</i>	16.7 or lower
	<i>Voltage, Freq, Ph (V-Hz, Ph)</i>	230,60,1	<i>Voltage, Freq, Ph (V-Hz, Ph)</i>	230,60,1
	<i>EER (Kj/h-W)</i>	12.9 or higher	<i>EER (Kj/h-W)</i>	12.9 or lower
		<i>Includes masonry works and painting</i>	<i>Includes masonry works and painting</i>	
	<i>Warranty: 5 years on motor compressor and 1 year on parts & services including free check-up and washing within the first year of the warranty period</i>	<i>Warranty: 5 years on motor compressor and 1 year on parts & services including free check-up and washing within the first year of the warranty period</i>		
2.	AIR CONDITIONING UNIT, WALL MOUNTED, 1.5 HP, SPLIT TYPE, NON-INVERTER with INSTALLATION COST - CON	AIR CONDITIONING UNIT, WALL MOUNTED, 1.5 HP, SPLIT TYPE, NON-INVERTER with INSTALLATION COST - CON		
	<i>Qty/ Unit: 2 units</i>	<i>Qty/ Unit: 2 units</i>		
	<i>Brand: (pls. indicate brand)</i>	<i>Brand: (pls. indicate brand)</i>		
	<i>Model: (pls. specify model)</i>	<i>Model: (pls. specify model)</i>		
	<i>Capacity (Tonner)</i>	1.5	<i>Capacity (HP)</i>	1.5
	<i>Power Input (W)</i>	1,500 or lower	<i>Power Input (W)</i>	1,500 or lower
	<i>Rated Current (A)</i>	4.0 or lower	<i>Rated Current (A)</i>	4.0 or higher
	<i>Voltage, Freq, Ph (V-Hz, Ph)</i>	230-60-1	<i>Voltage, Freq, Ph (V-Hz, Ph)</i>	230-60-1
	<i>EER (Kj/h-W)</i>	15.0 or higher	<i>EER (Kj/h-W)</i>	15.0 or lower
		<i>Includes masonry works and painting</i>	<i>Includes masonry works and painting</i>	
	<i>Includes indoor unit, outdoor unit, remote control, user manual and warranty card</i>	<i>Includes indoor unit, outdoor unit, remote control, user manual and warranty card</i>		
	<i>Warranty: 5 years on motor compressor and 1 year on parts & services including free check-up and washing within the first year of the warranty period</i>	<i>Warranty: 5 years on motor compressor and 1 year on parts & services including free check-up and washing within the first year of the warranty period</i>		



West Visayas State University

(Formerly Iloilo Normal School)

Bids and Awards Committee Secretariat Office/ Procurement Section

Luna St., La Paz, Iloilo City 5000

Iloilo, Philippines

* Trunkline: (063) (033) 320-0870 loc1103/1104 * Telefax No.: (033) 320-0879

* Website: www.wvsu.edu.ph * Email Address: bac@wvsu.edu.ph



SCP000194Q

Item No.	Description		Corrections/ Amendments/ Instructions	
3.	AIR CONDITIONING UNIT, WALL MOUNTED 1 HP, SPLIT TYPE, INVERTER WITH INSTALLATION COST - COM		AIR CONDITIONING UNIT, WALL MOUNTED 1 HP, SPLIT TYPE, INVERTER WITH INSTALLATION COST - COM	
	<i>Qty/ Unit: 2 units</i>		<i>Qty/ Unit: 2 units</i>	
	Brand: (pls. indicate brand)		Brand: (pls. indicate brand)	
	Model: (pls. specify model)		Model: (pls. specify model)	
	Power Consumption	400-910 (W)	Power Consumption	400-910 (W)
	Rated Current (A)	3.0 or lower	Rated Current (A)	3.0 or higher
	Cooling Capacity	13,665 Kj/h	Cooling Capacity	9,000 Kj/h or higher
	Includes masonry works and painting		Includes masonry works and painting	
	Includes indoor unit, outdoor unit, remote control, user manual and warranty card		Includes indoor unit, outdoor unit, remote control, user manual and warranty card	
	Warranty: 5 years on motor compressor and 1 year on parts & services including free check-up and washing within the first year of the warranty period		Warranty: 5 years on motor compressor and 1 year on parts & services including free check-up and washing within the first year of the warranty period	
4.	AIR CONDITIONING UNIT, CEILING MOUNTED, 2.5 TONNER, SPLIT AND INVERTER TYPE - COM		AIR CONDITIONING UNIT, CEILING MOUNTED, 2.5 TONNER, SPLIT AND INVERTER TYPE - COM	
	<i>Qty/ Unit: 1 unit</i>		<i>Qty/ Unit: 1 unit</i>	
	Brand: (pls. indicate brand)		Brand: (pls. indicate brand)	
	Model: (pls. specify model)		Model: (pls. specify model)	
	Features	2.5 Tonner, Inverter, Ceiling Mounted, Split Type	Features	2.5 Tonner, Inverter, Ceiling Mounted, Split Type
	Power Supply	220V	Power Supply	220V
	Power Consumption	1,200-2,800W	Power Consumption	1,200-2,800W
	Cooling Capacity	13,495 – 26,000 Kj / h	Cooling Capacity	13,495 – 26,000 Kj / h
	Rated Current (A)	9.0 or lower	Rated Current (A)	9.0 or higher
	Includes masonry works and painting		Includes masonry works and painting	
	Includes indoor unit, outdoor unit, remote control, user manual and warranty card		Includes indoor unit, outdoor unit, remote control, user manual and warranty card	
	Warranty: 5 years on motor compressor and 1 year on parts & services including free check-up and washing within the first year of the warranty period		Warranty: 5 years on motor compressor and 1 year on parts & services including free check-up and washing within the first year of the warranty period	
5.	AIR CONDITIONING UNIT, WINDOW TYPE, 2.0 HP, NON- INVERTER, MANUAL - UCA		AIR CONDITIONING UNIT, WINDOW TYPE, 2.0 HP, NON- INVERTER, MANUAL - UCA	
	<i>Qty/ Unit: 1 unit</i>		<i>Qty/ Unit: 1 unit</i>	
	Brand: (pls. indicate brand)		Brand: (pls. indicate brand)	
	Model: (pls. specify model)		Model: (pls. specify model)	
	Phase	Single	Phase	Single
	Volts	230V	Volts	230V
	Frequency	60Hz	Frequency	60Hz
	Capacity	19100KJ/H	Capacity	19100KJ/H or lower
	Current	8.4 Amp.	Current	8.4 Amp.
	Power Input	1801 W	Power Input	1801 W
	EER	10.6	EER	10.6
	LRA	40	LRA	40
	Warranty: 5 years on motor compressor and 1 year on parts & services including free check-up and washing within the first year of the warranty period		Warranty: 5 years on motor compressor and 1 year on parts & services including free check-up and washing within the first year of the warranty period	



West Visayas State University

(Formerly Iloilo Normal School)

Bids and Awards Committee Secretariat Office/ Procurement Section

Luna St., La Paz, Iloilo City 5000

Iloilo, Philippines

* Trunkline: (063) (033) 320-0870 loc1103/1104 * Telefax No.: (033) 320-0879

* Website: www.wvsu.edu.ph * Email Address: bac@wvsu.edu.ph



SCP000194Q

Item No.	Description		Corrections/ Amendments/ Instructions	
6.	<i>AIR CONDITIONING UNIT, WINDOW TYPE, 2.0 HP, NON- INVERTER, MANUAL – Pres. Office</i>		<i>AIR CONDITIONING UNIT, WINDOW TYPE, 2.0 HP, NON- INVERTER, MANUAL – Pres. Office</i>	
	<i>Qty/ Unit: 2 units</i>		<i>Qty/ Unit: 2 units</i>	
	<i>Brand: (pls. indicate brand)</i>		<i>Brand: (pls. indicate brand)</i>	
	<i>Model: (pls. specify model)</i>		<i>Model: (pls. specify model)</i>	
	<i>Phase</i>	<i>Single</i>	<i>Phase</i>	<i>Single</i>
	<i>Volts</i>	<i>230V</i>	<i>Volts</i>	<i>230V</i>
	<i>Frequency</i>	<i>60Hz</i>	<i>Frequency</i>	<i>60Hz</i>
	<i>Capacity</i>	<i>19100KJ/H</i>	<i>Capacity</i>	<i>19100KJ/H or lower</i>
	<i>Current</i>	<i>8.4 Amp.</i>	<i>Current</i>	<i>8.4 Amp.</i>
	<i>Power Input</i>	<i>1801 W</i>	<i>Power Input</i>	<i>1801 W</i>
	<i>EER</i>	<i>10.6</i>	<i>EER</i>	<i>10.6</i>
	<i>LRA</i>	<i>40</i>	<i>LRA</i>	<i>40</i>
7.	<i>AIR CONDITIONING UNIT, WINDOW TYPE, 1.5 HP, INVERTER – AVC</i>		<i>AIR CONDITIONING UNIT, WINDOW TYPE, 1.5 HP, INVERTER – AVC</i>	
	<i>Qty/ Unit: 7 units</i>		<i>Qty/ Unit: 7 units</i>	
	<i>Brand: (pls. indicate brand)</i>		<i>Brand: (pls. indicate brand)</i>	
	<i>Model: (pls. specify model)</i>		<i>Model: (pls. specify model)</i>	
	<i>Cooling Capacity</i>	<i>5,200-14,000Kj/hr</i>	<i>Cooling Capacity</i>	<i>5,200-14,000Kj/hr</i>
	<i>Power Consumption</i>	<i>465-1280Watts</i>	<i>Power Consumption</i>	<i>465-1280Watts</i>
	<i>Energy Efficiency Ratio</i>	<i>11.2-10.9 Kj/W-hr</i>	<i>Energy Efficiency Ratio</i>	<i>11.2-10.9 Kj/W-hr</i>
	<i>Sound Level @ low</i>	<i>48 dB</i>	<i>Sound Level @ low</i>	<i>48 dB – 60 dB</i>
	<i>Current</i>	<i>4.0 Amperes or lower</i>	<i>Current</i>	<i>4.0 Amperes or higher</i>

II. Section VIII. Checklist of Technical and Financial Documents:

Item No.	Description	Corrections/ Amendments/ Instructions
I.	<i>TECHNICAL COMPONENT ENVELOPE</i>	<i>TECHNICAL COMPONENT ENVELOPE</i>
		(Bidder should submit only one copy labeled “ORIGINAL”)
II.	<i>FINANCIAL COMPONENT ENVELOPE</i>	<i>FINANCIAL COMPONENT ENVELOPE</i>
		(Bidder should submit only one copy labeled “ORIGINAL”)

For guidance and information of all concerned.

JULIUS B. UNДАР

Chairperson, Bids and Awards Committee