



SUPPLEMENTAL/BID BULLETIN

Project Reference No. **IB No. 22-32**
 Name of the Project **One Lot Modification/Enhancement of Sewage Treatment Plant (Re-bidding)**
 Location of the Project **WVSU Medical Center**

ADDENDUM NO. 01 - 2022

July 13, 2022

This Addendum No. 01 is issued to modify or amend items in the Bidding Documents. Attached is the revised Section VII. Technical Specifications (pages 18-19). These shall form an integral part of the Bidding Documents.

A. Section VII. Technical Specifications

Item No.	Item Description	Qty	Unit	Corrections/Modifications/Amendments
	One Lot Modification/Enhancement of Sewage Treatment Plant (Re-bidding)	1	Lot	
	Design and Build - Improvement of Wastewater Treatment Plant			
	Scope of Work:			
	- Design and install necessary equipment to reprocess the existing waste water product of the Wastewater Treatment Plant to qualify to the latest DENR water quality guidelines and general effluent standards			- Design and install necessary equipment to reprocess the existing waste water product of the Wastewater Treatment Plant to qualify to the latest DENR water quality guidelines and general effluent standards (Class C)

For guidance and information of all concerned.

MARY EUGENE C. ORILLO
Chairperson
Bids and Awards Committee

Received by the Bidder:

Printed Name & Signature

Name of Bidder/Company

Date: _____

Section VII. Technical Specifications

IB No. UMC 22-32 One Lot Modification/Enhancement of Sewage Treatment Plant (Re-bidding)
 (Revised as indicated in the Bid Bulletin)

Item No.	Specification	Statement of Compliance			
		[Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]			
	One Lot Modification/Enhancement of Sewage Treatment Plant (Re-bidding)	Qty	Unit	Brand	Statement of Compliance
	One Lot Modification/Enhancement of Sewage Treatment Plant (Re-bidding)	1	Lot		
	Design and Build - Improvement of Wastewater Treatment Plant				
	Scope of Work:				
	- Design and install necessary equipment to reprocess the existing waste water product of the Wastewater Treatment Plant to qualify to the latest DENR water quality guidelines and general effluent standards (<i>Class C</i>)				
	1. Color				
	2. Temperature				
	3. pH				
	4. BOD				
	5. Total Suspended Solid				
	6. Fecal Coliform				
	7. Ammonia				
	8. Nitrate as No ³ N				
	9. Phosphate				
	10. Oil & Grease				
	11. Surfactants (MBAS)				
	CONDITIONS:				
	A. To submit during the bid opening				
	1. Supply of equipment and materials based on the design of the system(provide certification)				
	2. Influent volume capacity - 200m ³ /day (domestic waste only)(provide certification)				
	3. Electrical devices and wire are compatible with the existing main power supply of 230V 60 Hz (provide certification)				
	4. Submit schematic diagram of the project offered				
	5. Submit treatment process showing the efficiency of each process.				
	6. Submit computation of the volume of wastewater to be treated.				
	B. To be submitted by the winning bidder after contract implementation and before processing the payment				
	1. Submit As-built plan signed by Sanitary Engineer/PME				

Section VII. Technical Specifications

*IB No. UMC 22-32 One Lot Modification/Enhancement of Sewage Treatment Plant (Re-bidding)
(Revised as indicated in the Bid Bulletin)*

Item No.	Specification	Statement of Compliance			
		Qty	Unit	Brand	Statement of Compliance
	One Lot Modification/Enhancement of Sewage Treatment Plant				
	2. Submit Engineers report for the application of DENR Discharge Permit.				
	3. Submit Operations Manual				
	4. Testing and Commissioning Report				
	Inclusions: (Provide Certification)				
	1. One year quarterly maintenance check-up				
	2. One year quarterly water sampling Laboratory test result for self monitoring report (SMR) requirement.				
	3. One year free supply of chemicals according to the design of the bidder				
	4. Discharge Permit from DENR and Laboratory results of the wastewater indicating pass or satisfactory shall be the pre-requisite of the Final Billing.				
	5. All equipment must have redundancy with flowmeter for monitoring of influent and effluent volumetric flowrate.				
	6. One year warranty for equipment and workmanship.				
	Duration: 120 calendar days				

Name of Bidder: _____

Submitted by: _____
(Printed Name and Signature)

Designation: _____

Date: _____