



WEST VISAYAS STATE UNIVERSITY MEDICAL CENTER

E. Lopez St., Jaro, Iloilo City

"PhilHealth Accredited Health Care Provider"

Tel No.: (033) 320 2431 | Fax No.: (033) 3202623 | Email Address: medcenter@wvsu.edu.ph



SUPPLEMENTAL/BID BULLETIN

Project Reference No. **IB No. 22-55**

Name of the Project **One Lot Modification/Enhancement of Sewage Treatment Plant (Re-bidding)**

Location of the Project **WVSU Medical Center**

ADDENDUM NO. **01 - 2022**
December 12, 2022

This Addendum No. 01 is issued to modify or amend items in the Bidding Documents. Attached is the revised Section VI. Specifications/Terms of Reference (pages 19-29), Section VIII. Bill of Quantities (page 33). These shall form an integral part of the Bidding Documents.

A. Section VI. Specifications/Terms of Reference

Item No.	Item Description	Qty	Unit	Corrections/Modifications/Amendments
	One Lot Modification/Enhancement of Sewage Treatment Plant (Re-bidding)	1	Lot	
	D. Conceptual Design/Project components			D. Conceptual Design/Project components
				<p>Delete: The first component of the project calls for the provision of materials, labor and equipment for the modification/ enhancement of sewage treatment plant (Design and Build-Improvement of Waste Water Treatment Plant). (see attached plans). Also included in the reinforced concrete works are manhole covers and stainless ladders, and various vertical pumps and electrical support works. (See Bill of Quantities, Summary of Materials, and Materials Specifications).</p> <p>The second component of the project involves design and construction of a wastewater treatment plant having a minimum influent design capacity of Two Hundred (200) Cubic Meters (cu.....m) per day. Treated wastewater shall pass the latest DENR Administrative Order (DAO) pertaining to water quality guidelines and general effluent standards specific for industries such hospitals and other related facilities enumerated below:</p>
	E. Scope or Deliverables for Underground Water Storage and Accessories			Delete
	F. Scope or Deliverables for Wastewater Treatment Plant			E. Scope or Deliverables for Wastewater Treatment Plant
	F. a. Pre-construction Phase 4. Structural design (if any) with all design parameters of structural members shall be in accordance to the latest edition of the National Structural Code of the Philippines.			Delete
	G. Implementation Arrangement			F. Implementation Arrangement



WEST VISAYAS STATE UNIVERSITY MEDICAL CENTER

E. Lopez St., Jaro, Iloilo City

"PhilHealth Accredited Health Care Provider"

Tel No.: (033) 320 2431 | Fax No.: (033) 3202623 | Email Address: modcenter@wvsu.edu.ph



SUPPLEMENTAL/BID BULLETIN


Project Reference No. **IB No. 22-55**
 Name of the Project **One Lot Modification/Enhancement of Sewage Treatment Plant (Re-bidding)**
 Location of the Project **WVSU Medical Center**

ADDENDUM NO. 01 - 2022
 December 12, 2022

Item No.	Item Description	Qty	Unit	Corrections/Modifications/Amendments
	H. Eligibility Requirements (Refer to Bid Tender Documents)			G. Eligibility Requirements (Refer to Bid Tender Documents)
	I. Manpower Requirements (Refer to Bid Tender Documents)			H. Manpower Requirements (Refer to Bid Tender Documents)
	J. Approved Budget Cost			I. Approved Budget Cost
	K. Time Frame – 120 Calendar Days			J. Time Frame – (90 Calendar Days)
	SUBJECT: DESIGN PARAMETERS STRUCTURAL/CIVIL WORKS			SUBJECT: DESIGN PARAMETERS STRUCTURAL/CIVIL WORKS - DELETE

B. Section VIII. Bill of Quantities (see attached Revised BOQ-Page 33)

For guidance and information of all concerned.


MARY EUGENE C. ORILLO
 Chairperson
 Bids and Awards Committee

Received by the Bidder:

Printed Name & Signature

Name of Bidder/Company

Date: _____