



SUPPLEMENTAL/BID BULLETIN

Project Reference No. **IB No. 23-52**
Name of the Project **One Lot Supply, Delivery, Installation, Testing and Commissioning of Air Conditioning Units**
Location of the Project **WVSU Medical Center**

ADDENDUM NO. 02 - 2023

September 25, 2023

This Addendum No. 01 is issued to modify or amend items in the Bidding Documents. Attached are the **Revised Section III. Bid Data Sheet (page 12), Section VII. Technical Specifications (pages 18-19) and Price Schedules for Goods (pages 23-24)**. These shall form an integral part of the Bidding Documents.

A. Technical Specifications

As indicated in the Bidding Documents				Corrections/Modifications/Amendments <i>(in bold & italicized words)</i>
Item No.	Item Description	Qty	Unit	
6	Room Airconditioning Units	18	units	
	Brand New			
	1.5 Hp, Window Type, Non-inverter, Manual			
	220V-240V, 60Hz, Single Phase			
	Bracket size: L- 668mm x W- 560mm x H- 375mm			<i>Aircon Dimension: L-650-668mm x W- 540-560mm x H- 350-375mm</i>

For guidance and information of all concerned.


CESAR Q. TRONCO, R.N.
Chairperson
Bids and Awards Committee

Received by the Bidder:

Printed Name & Signature

Name of Bidder/Company

Date: _____

Section III. Bid Data Sheet

*IB No. 23-52 One Lot Supply, Delivery, Installation, Testing and Commissioning of Air Conditioning Units
(Revised as indicated in the Bid Bulletin No. 02-2023)*

ITB Clause					
5.3	For this purpose, contracts similar to the Project shall be: <ol style="list-style-type: none"> a. <u>Supply, Delivery, Installation, Testing and Commissioning of Air Conditioning Units.</u> b. Completed within 2 years prior to the deadline for the submission and receipt of bids. 				
7.1	N/A				
12	The price of the Goods shall be quoted DDP <u>in Philippines</u> or the applicable International Commercial Terms (INCOTERMS) for this Project.				
14.1	The bid security shall be in the form of a Bid Securing Declaration, or any of the following forms and amounts: <ol style="list-style-type: none"> a. The amount of not less than <u>PhP 91,365.60</u> [Indicate the amount equivalent to two percent (2%) of ABC], if bid security is in cash, cashier's/manager's check, bank draft/guarantee or irrevocable letter of credit; or b. The amount of not less than <u>PhP 228,414.00</u> [Indicate the amount equivalent to five percent (5%) of ABC] if bid security is in Surety Bond. 				
19.3	<u>IB No. 23-52 One Lot Supply, Delivery, Installation, Testing and Commissioning of Air Conditioning Units</u>				
	Item No.	Description	Qty.	Unit	Ceiling Price
	1	Room Airconditioning Units	6	units	637,470.00
		Brand New			
		4.0 Hp, Split Type, Ceiling Cassette, 4-way, Non-inverter			
		220V-240V, 60Hz, Single Phase			
	2	Room Airconditioning Units	28	units	1,761,760.00
		Brand New			
		2.5 Hp, Split Type, Wall Mounted, Non-inverter			
		220V-240V, 60Hz, Single Phase			
	3	Room Airconditioning Units	17	units	742,390.00
		Brand New			
		1.5 Hp, Split Type, Wall Mounted, Non-inverter			
		220V-240V, 60Hz, Single Phase			
	4	Room Airconditioning Units	3	units	118,260.00
		Brand New			
		1.0 Hp, Split Type, Wall Mounted, Non-inverter			
		220V-240V, 60Hz, Single Phase			
	5	Room Airconditioning Units	18	units	512,910.00
		Brand New			
		2.0 Hp, Window Type, Non-inverter, Manual			
		220V-240V, 60Hz, Single Phase			
		With Bracket			
	6	Room Airconditioning Units	18	units	417,510.00
		Brand New			
		1.5 Hp, Window Type, Non-inverter, Manual			
		220V-240V, 60Hz, Single Phase			
		Aircon Dimension: L- 650-668mm x W- 540-560mm x H- 350-375mm			
	7	Room Airconditioning Units	4	units	377,980.00
		Brand New			
		3.0 Tons, Split Type, Floor Mounted, Non-inverter			
		220V-240V, 60Hz, Single Phase			
		TOTAL ABC FOR THE PROJECT			4,568,280.00
20.2	<i>No additional Requirements.</i>				
21.2	<i>No additional contract documents</i>				

Section VII. Technical Specifications

IB No. UMC 23-52 One Lot Supply, Delivery, Installation, Testing and Commissioning of Air Conditioning Units
(Revised as indicated in the Bid Bulletin No. 02-2023)

Item No.	Specification	Statement of Compliance				
		[Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]				
One Lot Supply, Delivery, Installation, Testing and Commissioning of Air Conditioning Units		Qty	Unit	Brand	Model	Statement of Compliance
1	Room Airconditioning Units	6	units			
	Brand New					
	4.0 Hp, Split Type, Ceiling Cassette, 4-way, Non-inverter					
	220V-240V, 60Hz, Single Phase					
2	Room Airconditioning Units	28	units			
	Brand New					
	2.5 Hp, Split Type, Wall Mounted, Non-inverter					
	220V-240V, 60Hz, Single Phase					
3	Room Airconditioning Units	17	units			
	Brand New					
	1.5 Hp, Split Type, Wall Mounted, Non-inverter					
	220V-240V, 60Hz, Single Phase					
4	Room Airconditioning Units	3	units			
	Brand New					
	1.0 Hp, Split Type, Wall Mounted, Non-inverter					
	220V-240V, 60Hz, Single Phase					
5	Room Airconditioning Units	18	units			
	Brand New					
	2.0 Hp, Window Type, Non-inverter, Manual					
	220V-240V, 60Hz, Single Phase					
	With Bracket					
6	Room Airconditioning Units	18	units			
	Brand New					
	1.5 Hp, Window Type, Non-inverter, Manual					
	220V-240V, 60Hz, Single Phase					
	Aircon Dimension: L-650-668mm x W- 540-560mm x H- 350-375mm					
7	Room Airconditioning Units	4	units			
	Brand New					
	3.0 Tons, Split Type, Floor Mounted, Non-inverter					
	220V-240V, 60Hz, Single Phase					

Section VII. Technical Specifications

*IB No. UMC 23-52 One Lot Supply, Delivery, Installation, Testing and Commissioning of Air Conditioning Units
(Revised as indicated in the Bid Bulletin No. 02-2023)*

Item No.	Specification	Statement of Compliance				
		[Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]				
	One Lot Supply, Delivery, Installation, Testing and Commissioning of Air Conditioning Units	Qty	Unit	Brand	Model	Statement of Compliance
	Inclusive of:					
	– Outdoor bracket, Outdoor Nema Type 3R circuit breaker, Standard Copper Tube, 1"thickness rubber insulator, insulation of drain pipe, EMT electrical conduit and other necessary materials for the installation and functionality of the ACU.					
	Warranty:					
	– 5 years on compressor					
	– 1 year on parts and services					
	Conditions:					
	– Conduct site inspection to asses the necessary materials for the operation of the ACU.					
	– Installation of electrical wiring to the existing tapping point or power panel of WVSUMC will be included in the scope of work.					
	–Submit As-built plan, Signed by PME.					
	--- Nothing Follows ---					

Name of Bidder: _____

Submitted by: _____
(Printed Name and Signature)

Designation: _____

Date: _____

Price Schedule for Goods Offered from Within the Philippines
[shall be submitted with the Bid if bidder is offering goods from within the Philippines]

For Goods Offered from Within the Philippines

Name of Bidder _____

Project ID No. UMC 23-52 Page 1 of 2

Revised as indicated in the Bid Bulletin No. 02-2023

1	2	3	4	5	6	7	8	9	10
Item	Description	Country of origin	Quantity	Unit price EXW per item	Transportation and all other costs incidental to delivery, per item	Sales and other taxes payable if Contract is awarded, per item	Cost of Incidental Services, if applicable, per item	Total Price, per unit (col 5+6+7+8)	Total Price delivered Final Destination (col 9) x (col 4)
	One Lot Supply, Delivery, Installation, Testing and Commissioning of Air Conditioning Units		1 Lot						
1	Room Airconditioning Units		6 units						
	Brand New								
	4.0 Hp, Split Type, Ceiling Cassette, 4-way, Non-inverter								
	220V-240V, 60Hz, Single Phase								
2	Room Airconditioning Units		28 units						
	Brand New								
	2.5 Hp, Split Type, Wall Mounted, Non-inverter								
	220V-240V, 60Hz, Single Phase								
3	Room Airconditioning Units		17 units						
	Brand New								
	1.5 Hp, Split Type, Wall Mounted, Non-inverter								
	220V-240V, 60Hz, Single Phase								
4	Room Airconditioning Units		3 units						
	Brand New								
	1.0 Hp, Split Type, Wall Mounted, Non-inverter								
	220V-240V, 60Hz, Single Phase								
5	Room Airconditioning Units		18 units						
	Brand New								
	2.0 Hp, Window Type, Non-inverter, Manual								
	220V-240V, 60Hz, Single Phase								
	With Bracket								

Price Schedule for Goods Offered from Within the Philippines
[shall be submitted with the Bid if bidder is offering goods from within the Philippines]

For Goods Offered from Within the Philippines

Name of Bidder _____

Project ID No. UMC 23-52 Page 2 of 2

Revised as indicated in the Bid Bulletin No. 02-2023

1	2	3	4	5	6	7	8	9	10
Item	Description	Country of origin	Quantity	Unit price EXW per item	Transportation and all other costs incidental to delivery, per item	Sales and other taxes payable if Contract is awarded, per item	Cost of Incidental Services, if applicable, per item	Total Price, per unit (col 5+6+7+8)	Total Price delivered Final Destination (col 9) x (col 4)
6	Room Airconditioning Units		18 units						
	Brand New								
	1.5 Hp, Window Type, Non-inverter, Manual								
	220V-240V, 60Hz, Single Phase								
	Aircon Dimension: L-650-668mm x W- 540-560mm x H-350-375mm								
7	Room Airconditioning Units		4 units						
	Brand New								
	3.0 Tons, Split Type, Floor Mounted, Non-inverter								
	220V-240V, 60Hz, Single Phase								
	TOTAL BID								

Name: _____

Legal Capacity: _____

Signature: _____

Duly authorized to sign the Bid for and behalf of: _____